

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME


CB TEST CERTIFICATE

Product	Plugs, socket-outlets and couplers for industrial purposes
Name and address of the applicant	LEGRAND FRANCE 6, Paul Nouel 76770 MALAUNAY France
Name and address of the manufacturer	LEGRAND FRANCE 6, Paul Nouel 76770 MALAUNAY France
Name and address of the factory	See annex <input checked="" type="checkbox"/> Additional Information on page 2
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See Annex
Trademark (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	Models Hypra 32A References : see annex
Additional information (if necessary may also be reported on page 2)	<input checked="" type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60309-1:1999(ed. 4) +A1:2005 +A2:2012 IEC 60309-2:1999(ed. 4) +A1:2005 +A2:2012
As shown in the Test Report Ref. No. which forms part of this Certificate	135754-672673

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 14/09/2017

Signature: **Didier BOURG**
Manager of Certification Operations

ANNEX

Name and address of the factories:**LEGRAND FRANCE**

ZI des Coutures, 519 rue Jules Ferry
02120 GUISE
France

LEGRAND France


670 route de Tendos
76690 FONTAINE LE BOURG
France



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 14/09/2017

Signature: **Didier BOURDES**
Manager of Certification Operations



ANNEX

REFERENCES, MAIN CHARACTERISTICS

Appliance Inlet						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P+E	200/250 V~	50/60Hz	6h	Metallic	0 528 62	
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 528 72	0 530 86
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 73	
32A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 528 63	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 528 73	0 530 90
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 528 64	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 528 74	0 530 91


Bended plug						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P+E	200/250 V~	50/60Hz	6h	Metallic	0 527 72	
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 527 62	
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 63	
32A	2P+E	380/415 V~	50/60Hz	9h	Plastic	0 529 62	
32A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 529 73	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 529 63	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 529 74	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 529 64	



LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 14/09/2017

Signature: **Didier BOUGES**
 Manager of Certification Operations



ANNEX


Connector						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P	20/25 V~	50/60Hz	----	Rubber	0 525 81	
32A	2P+E	100/130 V~	50/60Hz	4h	Plastic	0 519 82	
32A	3P+E	100/130 V~	50/60Hz	4h	Plastic	0 523 72	
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 527 82	0 530 76
32A	2P+E	200/250 V~	50/60Hz	6h	Rubber	0 527 92	
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 83	0 530 77
32A	3P+E	200/250 V~	50/60Hz	9h	Rubber	0 527 93	
32A	3P+N+E	120/208 V~ 144/250 V~	50/60Hz	9h	Plastic	0 527 84	
32A	3P+N+E	120/208 V~ 144/250 V~	50/60Hz	9h	Rubber	0 527 94	
32A	2P+E	380/415 V~	50/60Hz	9h	Plastic	0 529 82	
32A	2P+E	380/415 V~	50/60Hz	9h	Rubber	0 529 92	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 529 83	0 530 80
32A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 529 93	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 529 84	0 530 81
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 529 94	
32A	3P+E	440/460 V~	50/60Hz	11h	Plastic	0 523 52	
32A	3P+E	480/500 V~	50/60Hz	7h	Plastic	0 523 62	



LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 14/09/2017

Signature: **Didier BOUDES**
 Manager of Certification Operations



ANNEX

Panel Socket						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 527 02	
32A	3P+E	200/250 V~	50/60Hz	9h	Metallic	0 527 13	
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 03	
32A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 529 13	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 529 03	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 529 14	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 529 04	


Straight Plug						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P	20/25 V~	50/60Hz	----	Plastic	0 525 21	
32A	2P+E	100/130 V~	50/60Hz	4h	Plastic	0 519 42	
32A	3P+E	100/130 V~	50/60Hz	4h	Plastic	0 523 71	
32A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 527 42	0 530 56
32A	2P+E	200/250 V~	50/60Hz	6h	Rubber	0 527 52	
32A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 527 43	0 530 57
32A	3P+E	200/250 V~	50/60Hz	9h	Rubber	0 527 53	
32A	3P+N+E	120/208 V~ 144/250 V~	50/60Hz	9h	Plastic	0 527 44	
32A	3P+N+E	120/208 V~ 144/250 V~	50/60Hz	9h	Rubber	0 527 54	
32A	2P+E	380/415 V~	50/60Hz	9h	Plastic	0 529 42	
32A	2P+E	380/415 V~	50/60Hz	9h	Rubber	0 529 52	
32A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 528 43	
32A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 528 53	
32A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 529 43	0 530 60
32A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 529 53	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 528 44	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 529 44	0 530 61
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 528 54	
32A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 529 54	
32A	3P+E	440/460 V~	50/60Hz	11h	Plastic	0 523 51	
32A	3P+E	480/500 V~	50/60Hz	7h	Plastic	0 523 61	



LCIE – Laboratoire Central des Industries Electriques
 33, avenue du Général Leclerc – BP8
 FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 14/09/2017

Signature: **Didier BOURC**
 Manager of Certification Operations



ANNEX

Panel Socket						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
32A	2P	20/25 V~	50/60Hz	----	Plastic	0 525 01	
32A	3P+T	100/130 V~	50/60Hz	4h	Plastic	0 523 70	
32A	2P+T	200/250 V~	50/60Hz	6h	Metallic	0 527 32	
32A	3P+T	200/250 V~	50/60Hz	9h	Metallic	0 527 33	
32A	2P+T	380/415 V~	50/60Hz	9h	Metallic	0 529 32	
32A	3P+T	380/415 V~	50/60Hz	6h	Metallic	0 529 33	
32A	3P+N+T	380/415 V~	50/60Hz	6h	Metallic	0 529 34	
32A	3P+T	440/460 V~	50/60Hz	11h	Plastic	0 523 50	

Type of accessory	- Socket outlet - Plugs - Connectors
Rated operating voltage:	2P: 20/25 V 2P+E: 100/130 V, 200/250 V, 380/415 V 3P+E: 100/130 V, 200/250 V, 380/415 V, 440/460 V, 480/500 V 3P+N+E: 200/250 V, 200/346 V to 240/415 V
Rated current:	32 A
Degree of protection:	IP44, IP55, IP66/67
Standard sheet:	2-I and 2-II
Position of earthing contact:	4h, 6h, 7h, 9h, 11h
Keyway position:	with / without
Type of terminal:	Screw-type
Plugs and connectors	
Type of cable exit:	Straight / angled
Appliance inlet and socket-outlet	
- Type of installation:	panel type / surface type



LCIE – Laboratoire Central des Industries Electriques
33, avenue du Général Leclerc – BP8
FR 92 266 Fontenay aux Roses Cedex
www.lcie.fr

Date: 14/09/2017

Signature: **Didier BOURGES**
Manager of Certification Operations

