

## IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME


## CB TEST CERTIFICATE

Product	<b>Plugs, socket-outlets and couplers for industrial purposes</b>
Name and address of the applicant	<b>LEGRAND FRANCE</b> 6, rue Paul Nouel - CS 80008 76770 MALAUNAY FRANCE
Name and address of the manufacturer	<b>LEGRAND FRANCE</b> 6, rue Paul Nouel - CS 80008 76770 MALAUNAY FRANCE
Name and address of the factory	
Note: When more than one factory, please report on page 2	<input checked="" type="checkbox"/> Additional Information on page 2
Ratings and principal characteristics	See Annex
Trademark / Brand (if any)	LEGRAND
Customer's Testing Facility (CTF) Stage used	/
Model / Type Ref.	Models Hypra 63A References : see annex
Additional information (if necessary may also be reported on page 2)	Supersedes CBTC FR_700640 dated 24/04/2017, update of test report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60309-1:1999(ed. 4) +A1:2005 +A2:2012 IEC 60309-2:1999(ed. 4) +A1:2005 +A2:2012
As shown in the Test Report Ref. No. which forms part of this Certificate	169087-756216

This CB Test Certificate is issued by the National Certification Body

LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 28/01/2021

LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSESSignature:   
Julien Gauthier  
Certification Officer

## ANNEX

**Name and address of the factories:****LEGRAND FRANCE**

670 route de Tendos  
76690 FONTAINE LE BOURG  
FRANCE

**LEGRAND FRANCE**

DIVISION INDUSTRIE, ZI DES COUTURES,  
519 RUE JULES FERRY  
02120 GUISE  
FRANCE



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 28/01/2021



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature:   
Julien Gauthier  
Certification Officer

## ANNEX (Continued)

References, ratings and main characteristics:

Bended plug						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63A	2P+E	200/250 V~	50/60Hz	6h	Metallic	0 536 72	
63A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 538 63	
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 538 64	
63A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 538 73	
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 538 74	

Connector						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 536 82	0 593 86
63A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 536 83	0 593 87
63A	2P+E	200/250 V~	50/60Hz	6h	Rubber	0 536 92	
63A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 538 83	0 594 87
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 538 84	0 594 88
63A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 538 93	
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 538 94	



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)

Date: 28/01/2021



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature:   
Julien Gauthier  
Certification Officer

## ANNEX (Continued)

Panel Socket						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 536 22	0 593 26
63A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 536 23	0 593 27
63A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 538 23	0 594 27
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 538 24	0 594 28
63A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 538 33	
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 538 34	
63A	3P+E	480/500 V~	50/60Hz	7h	Plastic		0 594 29

Straight Plug						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 536 42	0 593 46
63A	3P+E	200/250 V~	50/60Hz	9h	Plastic	0 536 43	0 593 47
63A	2P+E	200/250 V~	50/60Hz	6h	Rubber	0 536 52	
63A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 538 43	0 594 47
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 538 44	0 594 48
63A	3P+E	380/415 V~	50/60Hz	6h	Rubber	0 538 53	
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Rubber	0 538 54	
63A	3P+E	480/500 V~	50/60Hz	7h	Plastic		0 594 49

Unit surface type socket						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 537 22	0 593 36
63A	3P+E	200/250 V~	50/60Hz	9h	Plastic		0 593 37
63A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 537 23	0 594 37
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 537 24	0 594 38
63A	3P+E	380/415 V~	50/60Hz	6h	Metallic	0 537 33	
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Metallic	0 537 34	



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

Signature:   
Julien Gauthier  
Certification Officer

Date: 28/01/2021

## ANNEX (End)

Appliance Inlet						References	
Current	Number of poles	Voltage	Frequency	Earthing position	Material	IP 44	IP 55-66-67
63A	2P+E	200/250 V~	50/60Hz	6h	Plastic	0 537 72	0 593 76
63A	3P+E	380/415 V~	50/60Hz	6h	Plastic	0 537 73	0 594 77
63A	3P+N+E	200/346 V~ 240/415 V~	50/60Hz	6h	Plastic	0 537 74	0 594 78

## Main characteristics :

Type of accessory	- Socket outlet - Plugs - Connectors
Rated operating voltage:	2P+E : 200/250 V 3P+E : 200/250 V, 380/415 V, 480/500 V, 3P+N+E: 200/346 V to 240/415 V
Rated current:	63 A
Degree of protection:	IP44, IP55, IP66/67
Standard sheet:	2-IIIa, 2-IVa
Position of earthing contact:	6h, 7h, 9h
Keyway position:	without
Type of terminal:	Screw-type
Plugs and connectors	
Type of cable exit:	Straight - angled
Appliance inlet and socket-outlet	
Type of installation:	panel type – surface-type



LCIE – Laboratoire Central des Industries Electriques  
33, avenue du Général Leclerc – BP8  
FR 92 266 Fontenay aux Roses Cedex  
[www.lcie.fr](http://www.lcie.fr)



LABORATOIRE CENTRAL DES  
INDUSTRIES ELECTRIQUES  
S.A.S au capital de 15.745.984 €  
RCS Nanterre B 408 363 174  
33 avenue du Général Leclerc  
F - 92266 FONTENAY AUX ROSES

*Julien Gauthier*

Signature: **Julien Gauthier**  
Certification Officer

Date: 28/01/2021